

METER TAILS

CLIPS AND FIXINGS

522.8.5




Regulation 522.8.5 requires every cable to be installed to avoid any undue mechanical strain and to make sure that there is no strain on the conductors and connections.

This includes consumer unit meter tails.

By the way, this is in addition to any other requirements to provide protection to tails at the point of entry into metal consumer unit enclosures etc.

Meter tails need to be fixed/clipped in order to avoid such strain.



For full details see BS7671 IET Wiring Regulations



WHY CHOOSE ANYTHING LESS?

WY2489R